

REGIONAL WATER QUALITY TESTING LABORATORY (RWTL) MUZAFFARPUR



Public Health Engineering Department, Government of Bihar

DRINKING WATER QUALITY TEST CERTIFICATE



Name of District : MUZAFFARPUR

Sampling Date-09.06.2026

Sample Reciving Date in Lab:-09.06.2026

PHYSICO-CHEMICAL & BACTERIOLOGICAL
TEST REPORT

Sample Collected By : Not Collected by us.

Source of Sample : Boring

Date of Testing : 10 .06 2026

Sample code-84 RWTL/Juan/2026

Valid up to-09 .06 2027

Name of Person/Organization/Location:	Jeewan International School, Singhia Hibban, Behind Chati mai mandir Banjariya , Motihari, East Champaran
--	--

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

Sl. No.	Parameters	Desirable Limit*	Permissible Limit* in absence of alternate source	Method of Testing Parameters	Results
1	pH Value	6.5-8.5	No relaxation	pH meter	6.98
2	Turbidity, NTU, Max	5	10	Nephelometric	1.00
3	Conductivity, μ mho/cm	-	-	Conductivity meter	541
4	Total Dissolved Solid, mg/l, Max.	500	2000	Conductivity meter	310
5	Total Hardness (as CaCO_3), mg/l, Max	300	600	EDTA method	226.00
6	Calcium (as Ca), mg/l, Max	75	200	EDTA method	56.00
7	Magnesium (as Mg), mg/l, Max	30	100	EDTA method	20.16
8	Chloride (as Cl), mg/l, Max.	250	1000	Titration	40.00
9	Alkalinity (as CaCO_3), mg/l, Max.	200	600	Titration	168
10	Iron (as Fe), mg/l, Max.	1	No relaxation	Phenonthroline	0.15

Note:-Fit for Drinking Purpose as Above Parameters.

Note: *(1) Drinking Water Specification First Revision -IS:10500:1991, Edition 2.2(2003-09)(Reaffirmed1993). (2) BDL = Below Detection Limit, (3) Testing Methods are taken by APHA 20th Edition. (4) NR = No Relaxation. (5) ND = Not Done.

**(a) Throughout any year. 95% of the samples should not contain coliform organisms in 100ml. (b) No sample should contain more than 10 coliform organisms per 100ml. (c) Coliform organisms should not be detected in 100ml of any two consecutive samples.


 Chemist 12/06/26
 RWTL Muzaffarpur
Chemist
RWTL Muzaffarpur

SAFE DRINKING WATER CERTIFICATE

No. 59

Dated: 12/06/26

It is certified that an inspection team headed by **Satya Prakash Azad (Chemist)** (Name of Officers with designation) from **P.H.E.D. Investigation Office** (Name of Department/ Office) Jeewan International School, Singhia Hibban, Behind Chati mai mandir Banjariya, Motihari, East Champaran (Name & Address of the School) on 10/06/2026 date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **One year**

Signature with Seal:

Name :

Designation:

To
The Principal,
Jeewan International School,
Singhia Hibban, Behind Chati mai mandir Banjariya,
Motihari, East Champaran.