

कार्यालय कार्यपालन यंत्री लोक स्वास्थ्य यांत्रिकी खण्ड पन्ना, म0प्र0

दूरभाष (कार्या.) 07732-252084, ई.मेल.: eephedpan@nic.in

क्रमांक / 817 / लैब / कायं. / लोस्वायां. / खंड / 2026 पन्ना, दिनांक : 07/4/26
प्रति,


✓ श्री लाला कमलापत सिंघानियां,
जे.के. सीमेंट पुरैना,
जिला पन्ना (म0प्र0)

विषय : जल परीक्षण कराए जाने बावत।

संदर्भ : आपका पत्र क्रमांक शून्य चालान दिनांक 06.04.2026

उपरोक्त विषयांतर्गत आपके संदर्भित पत्र द्वारा प्रेषित 01 जल नमूने का परीक्षण कर परीक्षण रिपोर्ट आपकी ओर आवश्यक कार्यवाही हेतु संलग्न कर प्रेषित है।

संलग्न : जल परीक्षण रिपोर्ट


कार्यपालन यंत्री
लोक स्वास्थ्य यांत्रिकी खंड
पन्ना (म0प्र0)

**WATER TESTING LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT PANNA**

DISTT. PANNA (M.P.)

ANALYSIS REPORT

Type of Sample : Water Sample
Particulars of sender : Shri Lala Kamlapat Singhaniya, J.K. Cement Puraina, Distt. Panna
Water Sample collected by: Shri Lala Kamlapat Singhaniya, J.K. Cement Puraina, Distt. Panna
Sample No. and Date : As below

Sample No. & Date	Place of collection & Details of sample						
02/06-04-2026	Tube Well, J.K. Cement Puraina, Distt. Panna (MP)						
Particulars to be filled in the Laboratory							
Date of Receipt : 06-04-2026							
					Tested on- 06-04-2026		
NATURE OF STUDY – CHEMICAL ANALYSIS							
	Characteristics	Unit	As per BIS-10500:2012 For Drinking water		Sample No.2	Result	
			Requirement (Desirable Limit)	Permissible Limit in the absence of alternate source			
PHYSICAL TESTS							
1	Temperature	°C					
2	Turbidity	NTU	1	5	2.5		
3	Colour	Hazen Unit	5	15			
4	Odour		unobjectionable	objectionable			
5	pH	pH scale	6.5 To 8.5	No Relaxation	7.5		
6	Total Hardness as CaCo ₃	mg/l	200	600	310		
7	Total Alkalinity as CaCo ₃	mg/l	200	600	110		
8	Chloride as Cl	mg/l	250	1000	180		
9	Nitrate as NO ₃	mg/l	45	45	16		
10	Total Dissolved Solids	mg/l	500	2000	469		
11	Iron	mg/l	0.1	0.3	0.1		
12	Sulphate as SO ₄	mg/l	200	400	32		
13	Fluoride as F	mg/l	1.0	1.5	0.4		
14	Manganese as Mn	mg/l	0.1	0.3	0.1		
15	Residual Chlorine as Cl ₂	mg/l	0.2	1.0	NIL		
BACTERIOLOGICAL TESTS							
16	M.PN of coliform	Per 100 ml	NIL	NIL	NIL		
17	Feacal Coliform	Per 100 ml	NIL	NIL	NIL		

Note :- Water Sample is potable.


DISTT. CO-ORDINATOR (WQMS)
WATER TESTING LABORATORY
PHED PANNA

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Shri - Prakash Chaturvedi, S.E.

(Name of Officers with designation) from Panna.....PHED

inspected the Lala Kamalpat Singhania Education Centre.....

(Name & Address of the school) on 06/04/2026.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 817..... dated 07/04/2026

of Panna Division..... (PHED Lab) certified that the

Lala Kamalpat Singhania Education Centre (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till


SAE, PHE Panna

Signature with Seal:

Name

Designation

Name & Address of the Office / Department


Executive Engineer

Civil Health Engrg. Division
Panna (M.P.)

To Lala Kamalpat Singhania
Education Centre, Amarganj Panna
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies