

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 045/2025

Dated: 09/01/2025

It is certified that an inspection team headed by Shri Pradeep Bhai C Patel,

(Name of Officers with designation) from Songadh Nagar Palika PHED

inspected the Drinking water

(Name & Address of the school) on(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. PK/TK/29/0426 dated 09/01/2025

of Pollucan Laboratories Pvt. Ltd. (PHED Lab) certified that

the Singhania Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Jan 2026

Signature with Seal:

Name: Pradeep Bhai C Patel


Designation: Technical Assistant

Name & Address of the Office / Department :


To

Singhania Public School
c/o J.K. Paper Ltd., Unit CM, Fort Songadh.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


सेनेटरी इन्स्पेक्टर
सोनगढ नगरपालिका
डि.तापी


Technical Assistant
Nagarpalika Songadh
Dist. Tapi

**TEST REPORT**

QF/7.8/35-WT

Page: 1 of 1

Customer's Name and Address :

M/s. J. K. PAPER LTD. PLOT NO. 6/2, P.O. CENTRAL PUMP MILL, FORT SONGADH, GUNSADA – 394660 TAL.: SONGADH, DIST.: TAPI, GUJARAT, INDIA. K/A. Mr. DURGESH MISHRA (MO.NO.: 93289 21078)	Test Report No. : PL/JK/24/0426 Issue Date : 09/01/2025 Customer's Ref. : W.O. No.: 2248003178 Date:04.07.2023
---	---

Sampling Location : SPS SCHOOL #	Quantity/No. of Samples : 05 Ltr/01
Description of Sample : Drinking Water	Protocol (Purpose) : QC
Date of Sampling : 28/12/2024	Lab ID : JK/2412/32
Sampling By : Pollucon Laboratories Pvt. Ltd.	Packing/Seal : Sealed
Sample Receipt Date : 30/12/2024	Date of Completion : 09/01/2025
Date of Starting of Test : 30/12/2024	

OBSERVATION*: SAMPLE FOUND CONFORMING AS PER IS 10500:2012 STANDARD FOR THE TESTED PARAMETERS.**RESULT TABLE**

SR. NO.	PARAMETERS	UNIT	RESULT	REQUIREMENT AS PER IS 10500:2012	TEST METHOD
1	Odour	--	Agreeable	Agreeable	IS 3025 (Part – 5)
2	Colour	Hazen	3.0	Max 5	IS 3025 (Part 4) Clause.5
3	Taste	--	Agreeable	Agreeable	IS 3025 (Part-8)
4	pH	--	7.71	6.5 - 8.5	IS 3025 (Part 11) Clause.2
5	Turbidity	NTU	0.12	Max 1	IS 3025 (Part – 10)
6	Total Dissolved Solids	mg/L	2.31	Max 500	IS 3025 (Part – 16)
7	Total Hardness	mg/L	58	Max 200	IS 3025 (Part 21) Clause.5
8	Residual Free Chlorine*	mg/L	Not Detected	0.2 Min if chlorine is used as disinfectant	IS 3025 (Part 26) Clause.7
9	Chloride	mg/L	44.9	Max 250	IS 3025 (Part 32) Clause.2
10	Total Alkalinity	mg/L	64	Max 200	IS 3025 (Part – 23)
11	Coliforms	/100 ml	Absent	Absent	IS 15185
12	Escherichia coli	/100 ml	Absent	Absent	IS 15185
13	Chemical Oxygen Demand (COD)	mg/L	8.0	Not Specified	APHA (23 rd Edition) 5220 B
14	Biochemical Oxygen Demand (BOD) (3 days at 27 °C)	mg/L	Not Detected	Not Specified	IS 3025 (Part-44)

: Detail given by customer. Detection Limit: Residual Free Chlorine:0.1 mg/L, BOD :1.0mg/L.


H. T. Shah
Lab. Manager


Sweety Jain
Microbiologist


Dr. Arun Bajpai
Lab Manager(Q)

Note: This report is subject to terms & conditions mentioned overleaf.

- Recognized by MoEF, New Delhi Under Sec. 12 of Environmental Protection Act, 1986
- GPCB approved
- ISO 14001 : 2004
- OHSAS 18001 : 2007
- ISO 9001 : 2008
- Schedule B auditor

"Pollucon House", Plot No.5/5, Opp.Balaji Industrial Society, Old Shantinath Silk Mill Lane, Near Gaytri Farsan Mart,
Navjivan Circle,Udhana Magdalla Road, Surat-395007, Gujarat, India.

Phone : 0261-2635750, 0261-2635751, 0261-2635775, 07016605174, WEB: www.polluconlab.com, E. mail: pollucon@gmail.com, info@polluconlab.com

સોનગઢ નગરપાલિકા

ફોર્ટ સોનગઢ ,તા. સોનગઢ જી.તાપી , પીન નં ૩૯૪૬૭૦
નં. એમ .યુ. એન / જહેર આરોગ્ય/વશી/, તારિખ : ૩૦/૦૧/૨૦૨૫ જા.નં.
ફોન : (૦૨૬૨૪) ૨૨૧૬૯૯, E mail : npbranch_son@yahoo.co.in


January 30 2025


CERTIFICATE

We hereby certify that the Singhania Public School, C/o JK Paper Ltd, Unit: CPM, Fort SONGADH, Dist.: Tapi is having adequate sanitation facility infrastructure; after personally verifying the infrastructure, we are issuing this certificate for CBSE affiliation on their demand. The details of sanitation infrastructure are as under:

Sr.No.	Location		Remarks
1	Ground Floor I. Principal Office II. For Visitor III. MI Room IV. Conference Hall V. Girls' toilet/Urinal VI. Boys' toilet/ urinal	1 1 1 1 4 Bath rooms 3 Wash basins 5 urinal pots 3 wash basins 4 bath rooms	Adequate Infrastructure To cater the need of sanitation requirement
2	First Floor I. Girls' toilet/urinal II. Boys' toilet/urinal	4 bath rooms 3 wash basins 5 urinal pots 3 wash basins 4 bath rooms	
3	First Floor I. Girls' toilet/urinal II. Boys' toilet/urinal	4 bath rooms 3 wash basins 5 urinal pots 3 wash basins 4 bath rooms	

Looking to the strength of girls and boys the infrastructure is adequate. This infrastructure can cater the need for additional strength of about 50% of existing strength


Sanitary Inspector
Songadh Nagar Palika
Dist.Tapi


Technical Assistant
Nagarpallika Songadh
Dist.Tapi