



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY
Plot No.01, Sector Knowledge Park-IV, Greater Noida
Distt.- Gautam Budh Nagar (UP)

Ref.: H.D./2025/ 2565

Date: 06/11/2025

SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Senior Manager (Health)** from **Greater Noida Industrial Development Authority, Plot No.-1, Sector Knowledge Park-IV, Greater Noida-201310 PHED** inspected the Greater Noida Industrial Development Authority inspected **Shri Ram Global School, HS-03, Techzon-VII, Greater Noida (West), Distt-G.B. Nagar (U.P.)** on 13.10.2025 certified that **Shri Ram Global School, HS-03, Techzone-VII, Greater Noida (West), Distt-G.B. Nagar (U.P.)** maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for **one year**.

Signature with Seal:

Name : **Rajesh Kumar**

Designation : Senior Manager (Health)

Name & Address of the Office / Department

Greater Noida Industrial Development Authority

Plot No.-1, Sector Knowledge Park-IV, Greater Noida

To,

Manager
Shri Ram Global School
HS-03, Techzone-VII, Greater Noida (West)
Distt-G.B. Nagar (U.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Water Test Report

Test Report Ref. No 24-25/310/1
 Sample Collected on: 27th, FEB., 2025
 Sample Collected in: PET 500 ml bottle

Sample Collected by: Mr. Sunil Kumar
 Sample Collected from: - Shri Ram Global School,
 HS-3, Tech Zone-7, Greater Noida West, U.P

S.No.	Parameter	Result	Desired Limit	Permissible Limit
A	General			
1	Taste	Agreeable	Agreeable	Agreeable
2	Odor	Unobjectionable	Unobjectionable	Unobjectionable
3	Color, In Hazen Unit	Acceptable	5	25
B	Physical			
4	Turbidity NTU	<1 NTU	5 NTU	10 NTU
5	Total Dissolved Solids mg/l	90	500	2000
6	Conductivity micros at 25°C	157	N.S.	N.S.
7	pH	7.10	6.5 - 8.5	No relaxation
C	Chemical			
8	Total Alkalinity (as CaCO ₃), mg/l	11	200	600
9	Total Chlorides (as Cl), mg/l	10	250	1000
10	Residential Free Chlorine PPM	NIL	0.2(min.)	-----
11	Total Hardness as CaCO ₃	30	300	600
12	Silica mg/l	NIL	1.0	50.0
13	Dissolved Iron (as Fe), mg/l	0.01	0.3	1.0
D	Bacterial			
14	E-Coli	Absent	Negative	No relaxation
15	Coliform MPN/100 ml	NIL	10	No relaxation

Remarks: The no. of parameters tested is 15 only. The results indicate that the Quality of water considered being desired limits for drinking as per IS: 10500, in regard to the parameters tested. The report is issued subject to the terms & conditions.

Sample Tested by:

Pintu Kumar
 (Lab. Assistant)
 Pintu kumar

Sample Tested on:-05th March, 2025

Checked By:

Mahender Singh
 (Q.C. Head)
 Mahender Singh

Date: 05-03-2025

